



CALL FOR TENDER: QMFA 017/2014

TITLE: Commissioning of Scaffolding at Palazzo Parisio, Merchant Street and Melita Street, Valletta.

Clarification Note 2

Reference is being to the question raised during the Site Visit held on Thursday 3rd April, 2014 when interested bidders asked regarding the anchorage of the scaffolding with the façade.

Reply:

The drilling of holes, where necessary, of a diameter not bigger than 5/8ths of an inch would be permissible. The resulting holes should then be filled by the contractor with a sand / hydraulic lime / *xahx* mixture (3:1:1 *circa*). The contractor should ensure that no metal studs are left in the wall as these could eventually corrode and cause damage to the façade.

Monday 7th April, 2014

Page 1 of 1